

## REPORT- PS-F Energy End-Use Summary for FM1

WEATHER FILE- New York CityNY TMY2

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
JAN													
THERM	10136.	0.	44891.	53257.	24.	208.	3319.	25233.	0.	0.	6307.	0.	143374.
MAX THERM/HR	23.7	0.0	74.8	246.3	0.8	4.3	8.1	55.1	0.0	0.0	17.4	0.0	366.0
DAY/HR	9/22	0/ 0	22/23	23/ 6	14/ 1	13/22	23/ 6	23/ 7	0/ 0	0/ 0	5/11	0/ 0	23/ 6
PEAK ENDUSE	11.3	0.0	72.2	246.3	0.0	0.3	8.1	23.9	0.0	0.0	4.0	0.0	
PEAK PCT	3.1	0.0	19.7	67.3	0.0	0.1	2.2	6.5	0.0	0.0	1.1	0.0	
FEB													
THERM	8930.	0.	39985.	35404.	14.	241.	2936.	22432.	0.	0.	5829.	0.	115770.
MAX THERM/HR	23.3	0.0	73.7	216.1	0.8	4.4	7.8	53.7	0.0	0.0	17.4	0.0	336.8
DAY/HR	14/22	0/ 0	4/23	26/ 6	3/ 1	3/ 3	26/ 6	26/ 7	0/ 0	0/ 0	1/11	0/ 0	26/ 6
PEAK ENDUSE	11.1	0.0	71.0	216.1	0.0	0.3	7.8	26.5	0.0	0.0	4.0	0.0	
PEAK PCT	3.3	0.0	21.1	64.2	0.0	0.1	2.3	7.9	0.0	0.0	1.2	0.0	
MAR													
THERM	9407.	0.	43215.	19612.	168.	323.	3113.	24030.	0.	0.	6433.	0.	106300.
MAX THERM/HR	21.9	0.0	70.7	121.0	9.8	4.4	7.3	50.9	0.0	0.0	17.4	0.0	238.3
DAY/HR	1/22	0/ 0	1/ 5	1/ 6	25/16	27/23	1/ 6	1/ 7	0/ 0	0/ 0	1/11	0/ 0	1/ 6
PEAK ENDUSE	10.7	0.0	68.8	121.0	0.0	0.4	7.3	26.3	0.0	0.0	3.9	0.0	
PEAK PCT	4.5	0.0	28.9	50.8	0.0	0.1	3.0	11.0	0.0	0.0	1.6	0.0	
APR													
THERM	8508.	0.	40855.	6354.	411.	460.	2856.	22090.	0.	0.	6116.	0.	87651.
MAX THERM/HR	21.2	0.0	69.8	92.5	9.9	4.4	7.0	49.9	0.0	0.0	17.4	0.0	206.8
DAY/HR	7/22	0/ 0	12/ 5	4/ 6	30/19	9/ 5	4/ 5	1/ 7	0/ 0	0/ 0	1/11	0/ 0	4/ 6
PEAK ENDUSE	10.4	0.0	66.7	92.5	0.0	0.4	6.9	26.1	0.0	0.0	3.8	0.0	
PEAK PCT	5.0	0.0	32.2	44.7	0.0	0.2	3.3	12.6	0.0	0.0	1.9	0.0	
MAY													
THERM	7608.	0.	39574.	1175.	3296.	273.	2792.	20260.	0.	0.	5856.	0.	80833.
MAX THERM/HR	20.8	0.0	69.0	56.9	20.5	4.3	6.8	49.2	0.0	0.0	16.4	0.0	170.6
DAY/HR	6/22	0/ 0	5/ 5	7/20	9/17	6/ 4	7/ 5	7/ 7	0/ 0	0/ 0	6/15	0/ 0	7/16
PEAK ENDUSE	12.6	0.0	48.5	53.6	0.0	0.7	2.7	36.1	0.0	0.0	16.4	0.0	
PEAK PCT	7.4	0.0	28.5	31.4	0.0	0.4	1.6	21.1	0.0	0.0	9.6	0.0	
JUN													
THERM	6404.	0.	34354.	0.	7171.	347.	2699.	17779.	0.	0.	5217.	0.	73971.
MAX THERM/HR	17.8	0.0	67.4	0.0	20.3	1.4	6.0	43.8	0.0	0.0	15.1	0.0	114.4
DAY/HR	13/22	0/ 0	1/ 5	0/ 0	12/21	16/23	30/ 1	1/ 7	0/ 0	0/ 0	19/15	0/ 0	19/15
PEAK ENDUSE	11.3	0.0	47.7	0.0	4.2	0.3	2.7	33.1	0.0	0.0	15.1	0.0	
PEAK PCT	9.9	0.0	41.7	0.0	3.7	0.3	2.4	28.9	0.0	0.0	13.2	0.0	
JUL													
THERM	6000.	0.	32408.	0.	10803.	465.	2777.	17001.	0.	0.	5000.	0.	74454.
MAX THERM/HR	15.7	0.0	63.2	0.0	24.0	1.7	5.9	40.7	0.0	0.0	14.0	0.0	112.5
DAY/HR	4/22	0/ 0	30/ 5	0/ 0	1/ 1	2/ 2	1/ 2	30/ 7	0/ 0	0/ 0	4/11	0/ 0	4/11
PEAK ENDUSE	11.6	0.0	47.0	0.0	5.0	0.3	2.8	31.8	0.0	0.0	14.0	0.0	
PEAK PCT	10.3	0.0	41.8	0.0	4.5	0.3	2.5	28.3	0.0	0.0	12.4	0.0	
AUG													
THERM	6308.	0.	33694.	0.	9724.	434.	2810.	17473.	0.	0.	4784.	0.	75226.
MAX THERM/HR	17.3	0.0	65.8	0.0	21.5	1.6	6.0	42.7	0.0	0.0	13.3	0.0	111.4
DAY/HR	16/22	0/ 0	10/ 5	0/ 0	25/ 1	26/23	13/ 4	5/ 7	0/ 0	0/ 0	15/11	0/ 0	15/11
PEAK ENDUSE	11.6	0.0	47.0	0.0	4.4	0.3	2.7	32.0	0.0	0.0	13.3	0.0	
PEAK PCT	10.4	0.0	42.2	0.0	4.0	0.3	2.5	28.7	0.0	0.0	11.9	0.0	

REPORT- PS-F Energy End-Use Summary for FM1

WEATHER FILE- New York CityNY TMY2

----- (CONTINUED) -----

SEP													
THERM	6758.	0.	35122.	24.	6690.	365.	2721.	17958.	0.	0.	4633.	0.	74272.
MAX THERM/HR	18.7	0.0	68.3	24.4	27.3	4.2	6.5	46.2	0.0	0.0	13.3	0.0	132.9
DAY/HR	19/22	0/ 0	24/ 5	20/ 6	6/ 4	19/24	20/ 5	20/ 7	0/ 0	0/ 0	20/11	0/ 0	20/ 6
PEAK ENDUSE	9.8	0.0	63.0	24.4	0.0	1.8	6.3	24.7	0.0	0.0	3.0	0.0	
PEAK PCT	7.4	0.0	47.4	18.3	0.0	1.4	4.7	18.5	0.0	0.0	2.3	0.0	
OCT													
THERM	8363.	0.	41431.	1285.	1428.	309.	2839.	21269.	0.	0.	5035.	0.	81959.
MAX THERM/HR	20.8	0.0	69.9	70.7	15.6	4.5	6.9	48.9	0.0	0.0	14.0	0.0	182.7
DAY/HR	30/22	0/ 0	2/ 5	31/ 6	10/13	12/23	31/ 5	30/ 7	0/ 0	0/ 0	30/11	0/ 0	31/ 6
PEAK ENDUSE	10.3	0.0	65.6	70.7	0.0	0.5	6.7	25.8	0.0	0.0	3.2	0.0	
PEAK PCT	5.6	0.0	35.9	38.7	0.0	0.3	3.7	14.1	0.0	0.0	1.7	0.0	
NOV													
THERM	8955.	0.	41383.	9862.	282.	358.	2895.	22381.	0.	0.	5266.	0.	91382.
MAX THERM/HR	22.2	0.0	70.9	127.6	4.8	4.5	7.3	50.7	0.0	0.0	15.1	0.0	244.8
DAY/HR	21/22	0/ 0	22/ 4	22/ 6	3/17	14/23	22/ 6	22/ 7	0/ 0	0/ 0	21/11	0/ 0	22/ 6
PEAK ENDUSE	10.8	0.0	69.1	127.6	0.0	0.3	7.3	26.2	0.0	0.0	3.4	0.0	
PEAK PCT	4.4	0.0	28.2	52.1	0.0	0.1	3.0	10.7	0.0	0.0	1.4	0.0	
DEC													
THERM	9821.	0.	43905.	30872.	113.	255.	3174.	24283.	0.	0.	5895.	0.	118318.
MAX THERM/HR	22.8	0.0	72.7	207.6	4.5	2.9	7.8	52.9	0.0	0.0	16.4	0.0	327.7
DAY/HR	3/22	0/ 0	3/23	4/ 6	9/15	18/ 1	4/ 6	4/ 7	0/ 0	0/ 0	4/11	0/ 0	4/ 6
PEAK ENDUSE	11.1	0.0	70.8	207.6	0.0	0.3	7.8	26.4	0.0	0.0	3.7	0.0	
PEAK PCT	3.4	0.0	21.6	63.4	0.0	0.1	2.4	8.1	0.0	0.0	1.1	0.0	
	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
THERM	97196.	0.	470818.	157844.	40122.	4039.	34929.	252190.	0.	0.	66370.	0.	1123510.
MAX THERM/HR	23.7	0.0	74.8	246.3	27.3	4.5	8.1	55.1	0.0	0.0	17.4	0.0	366.0
MON/DY	1/ 9	0/ 0	1/22	1/23	9/ 6	10/12	1/23	1/23	0/ 0	0/ 0	1/ 5	0/ 0	1/23
PEAK ENDUSE	11.3	0.0	72.2	246.3	0.0	0.3	8.1	23.9	0.0	0.0	4.0	0.0	
PEAK PCT	3.1	0.0	19.7	67.3	0.0	0.1	2.2	6.5	0.0	0.0	1.1	0.0	

FUEL USED TO GENERATE ELECTRICITY CONSUMED OFFSITE = 0. THERM